

NOTES:

- EXISTING CABLE SHALL BE CLEANED FREE OF ASPHALT CONTAMINATION AS REQUIRED PRIOR TO REINSTALLATION.
- 2) IF ASPHALT CONTAMINATION CAN NOT BE CLEANED, SIKA SARNAFIL REQUIRES A CONTINUOUS LAYER OF G 459 FLASHING UNDER LOCATION OF CABLE, HOT-AIR WELDED IN PLACE.
- 3) SIKA IS NOT RESPONSIBLE FOR LIGHTNING DAMAGE.
- 4) END LAPS OF COVERSTRIP ARE NOT TO BE WELDED



DETAIL NAME:

ALTERNATE FLASHING FOR LIGHTNING ROD CABLE

BUILDING TRUST

800-933-7452

SCALE: DATE: DETAIL NO .: N.T.S. 4/22 **CAN 7-8C**

CONSULTANT, ARCHITECT, ENGINEER AND/OR DESIGN PROFESSIONAL PRACTICES AND JUDGEMENT AND SHOULD NOT BE RELIED UPON FOR THAT PURPOSE, SIKA ASSUMES NO LIABILITY WITH RESPECT TO THE DESIGN OF THE ROOFING SYSTEM. THE CONSULTANT, ARCHITECT, ENGINEER IND/OR DESIGN PROFESSIONAL FOR A PARTICULAR PROJECT BEARS THE SOLE RESPONSIBILITY FOR THE DESIGN OF THE SYSTEM. FOR THE PREPARATION AND APPROVAL OF THE PROJECT SPECIFICATIONS, DETAILS, SHOP DRAWINGS AND FOR DETERMINING THEIR SUITABILITY FOR A ARTICULAR PROJECT OR APPLICATION. WHILE SIKA PROVIDES GENERAL INSTRUCTION FOR THE INSTALLATION OF ITS MATERIALS, AS WELL AS TRAINING FOR SIKA AUTHORISED APPLICATION. WHILE SIKA PROVIDES GENERAL INSTRUCTION FOR THE INSTALLATION OF ITS MATERIALS SOURCE.