



NOTES:

- 1) LES FONDS DE CLOUAGE (NOUV. OU EXIST.) DOIVENT ÊTRE FIXÉS CONFORMÉMENT AUX DOCUMENTS DU CONCEPTEUR DE PROJET OU AU CODE NATIONAL DU BÂTIMENT OU RÈGLEMENTS MUNICIPAUX OU AUX EXIGENCES DE COMPAGNIES D'ASSURANCE, SELON LES EXIGENCES LES PLUS STRICTES.
- 2) LA HAUTEUR MINIMUM DE FASCIA DOIT ÊTRE DE 3" OU SI REQUISE AUTREMENT POUR ÉTEINDRE UN MINIMUM DE 1-1/2" AU-DESSOUS DU FOND DE CLOUAGE.
- 3) LE DESSUS DU FASCIA (PARTIE HORIZONTALE) DOIT AVOIR UNE LARGEUR MINIMALE DE 4".
- 4) LES VIS UTILISÉES POUR FIXER SOIT, POUR LES BANDES D'AGRAFE CONTINUES OU POUR LES FASCIAS, DOIVENT PÉNÉTRER AU FOND DE CLOUAGE D'AU MOINS 1".
- 5) LES FIXATIONS/VIS DES BANDES D'AGRAFE DOIVENT RÉSISSER À UNE TRACTION MINIMALE DE 100 LBS, UTILISER LES VIS N° 8 MIN. ET PÉNÉTRANT DE 1" MINIMUM. PLACER LES FIXATIONS CENTRÉES DANS LA PIÈCE SUPÉRIEUR EN BOIS DU FOND DE CLOUAGE, OU À 1" DU BORD SUPÉRIEUR DES BANDES D'AGRAFE @ 4"C.C.
- 6) FIXER EN QUINCONCE À 4" C.C. ENTRE 1" ET 1-1/2" DU BORD ARRIÈRE DU DESSUS DES FASCIAS. LE RATIO MAXIMUM À RENCONTRER POUR LA DIMENSION (L) DE LA HAUTEUR DE FASCIA EST SUIVANT: 210 LPC @ 8", 310 LPC @ 6" ET 470 LPC @ 4" (LPC=LIVRES PAR PIED CARRÉ)
- 7) VOIR LE DÉTAIL CAN 1-1B POUR LES JOINTS DE TÔLE SARNACLAD

BUILDING TRUST
800-933-7452



DETAIL NAME:

**REBORD EN TÔLE
SARNACLAD**

SCALE:

N.T.S.

DATE:

06/22

DETAIL NO.:

CAN 1-1A_FR

AS A MANUFACTURER OF CONSTRUCTION PRODUCTS, SIKA CANADA INC. (SIKA) PROVIDES GENERIC DETAILS AS A GENERAL GUIDE FOR INFORMATION PURPOSES ONLY. SIKA MAY REVIEW DETAILS PREPARED BY THE CONSULTANT, ARCHITECT, ENGINEER AND/OR DESIGN PROFESSIONAL FOR A PROJECT SOLELY FOR THE PURPOSE OF DETERMINING IF A SIKA WARRANTY MAY BE ISSUED FOR THE PROJECT. THE GENERIC DETAILS AND/OR REVIEW OF DETAILS ARE NOT CONSTRUED AS APPROVAL OF DETAILS BY SIKA AND IS NOT BEING CONDUCTED IN LIEU OF SOUND CONSULTANT, ARCHITECT, ENGINEER AND/OR DESIGN PROFESSIONAL PRACTICES AND JUDGEMENT AND SHOULD NOT BE RELIED UPON FOR THAT PURPOSE. SIKA ASSUMES NO LIABILITY WITH RESPECT TO THE DESIGN OF THE ROOFING SYSTEM. THE CONSULTANT, ARCHITECT, ENGINEER AND/OR DESIGN PROFESSIONAL FOR A PARTICULAR PROJECT BEARS THE SOLE RESPONSIBILITY FOR THE DESIGN OF THE SYSTEM. FOR THE PREPARATION AND APPROVAL OF THE PROJECT SPECIFICATIONS, DETAILS, SHOP DRAWINGS AND FOR DETERMINING THEIR SUITABILITY FOR A PARTICULAR PROJECT OR APPLICATION. WHILE SIKA PROVIDES GENERAL INSTRUCTION FOR THE INSTALLATION OF ITS MATERIALS, AS WELL AS TRAINING FOR SIKA AUTHORISED APPLICATORS, THE MEANS AND METHODS USED BY THE CONTRACTOR FOR MATERIAL STORAGE, SUBSTRATE EVALUATION, SURFACE PREPARATION, AND THE INSTALLATION OF BOTH SIKA AND NON SIKA MATERIALS ARE THE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR MUST ALWAYS READ AND FOLLOW THE WARNINGS AND INSTRUCTIONS OF SIKA PRODUCT LABELS, TECHNICAL DATA SHEETS, AND MATERIAL SAFETY DATA SHEETS. ALL SALE OF SIKA PRODUCTS AND SERVICES ARE SUBJECT TO SIKA'S TERMS AND CONDITIONS OF SALE AVAILABLE AT WWW.CAN.SIKA.COM.