




COMPLIANCE TESTED by berkeley analytical

VOC Emission Test Certificate

Product Name: Sikaflex®-2C NS EZ Mix - 187658

Product Sample Information		Certificate Information	
Company:	Sika Corporation	Certificate No:	230901-03
Company Website:	www.sikausa.com	Certified By:	
Product Type:	Sealant – Joint - Windows		Raja S. Tannous, Laboratory Director
Date Produced:	7/31/2023	Date:	September 1, 2023

Reference Standard: California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario ¹	Individual VOCs of Concern ²		Formaldehyde ³		TVOC ⁴
	Criterion	Compliant?	Criterion	Compliant?	
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤0.5 mg/m ³
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	>0.5 – 4.9 mg/m ³

Product Coverage⁵: 8163 g/m² (see manufacturer’s letter attached for loading and use – windows application)

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 – 4.9 mg/m³, and ≥5.0 mg/m³
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- Collaborative for High Performance Schools, CHPS Core Criteria 3.0

Narrative: Sika Corporation selected a sample representative of its Sikaflex-2C NS EZ Mix - 187658 sealant product and submitted it on 6/19/2023 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 991-019-01A-Sep0823.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical’s scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE “AS IS” WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.



Sika Corporation · 995 Towbin Ave · Lakewood, NJ 08701

Alec Huang
Berkeley Analytical
815 Harbour Way South, Suite 6
Richmond, CA 94804

CONTACT

Florian Doebbel
Senior Product Manager
Mobile: +1 (848) 254-0004
doebbel.florian@us.sika.com

**SCENARIO FOR USE OF SIKAFLEX®-2C NS EZ MIX AND
SIKAFLEX®-2C NS ARCTIC**

Lakewood, 09/07/2023

Dear Alec,

The following are the guidelines for the major use of Sikaflex®-2c NS EZ Mix and Sikaflex®-2c NS Arctic.

For both the School Classroom and the Private Office, Sikaflex®-2c NS EZ Mix and Sikaflex®-2c NS Arctic would be predominantly applied as a perimeter seal for windows. The average bead size would be ½ inch wide by ¼ inch deep.

Attached please find the Product Data Sheets for Sikaflex®-2c NS EZ Mix and Sikaflex®-2c NS Arctic along with the Safety Data Sheets for Part A and B.

Best Regards,

Florian Doebbel

LEGAL NOTE

The information, and, in particular, the recommendations relating to the application and end-use of Sika products, are given in good faith based on Sika's current knowledge and experience of the products when properly stored, handled and applied under normal conditions in accordance with Sika's recommendations. In practice, the differences in materials, substrates and actual site conditions are such that no warranty in respect of merchantability or of fitness for a particular purpose, nor any liability arising out of any legal relationship whatsoever, can be inferred either from this information, or from any written recommendations, or from any other advice offered. The user of the product must test the products suitability for the intended application and purpose. Sika reserves the right to change the properties of its products. The proprietary rights of third parties must be observed. All orders are accepted subject to our current terms of sale and delivery. Users must always refer to the most recent issue of the local Product Data Sheet for the product concerned, copies of which will be supplied on request.

SIKA CORPORATION

995 Towbin Ave · Lakewood, NJ 08701 · USA
www.sikausa.com