



NOTES:

- 1) EXISTING CABLE SHALL BE CLEANED FREE OF ASPHALT CONTAMINATION AS REQUIRED PRIOR TO REINSTALLATION.
- 2) IF ASPHALT CONTAMINATION CAN NOT BE CLEANED, SIKA SARNAFIL REQUIRES A CONTINUOUS LAYER OF G 459 FLASHING UNDER LOCATION OF CABLE, HOT-AIR WELDED IN PLACE.
- 3) A SEPERATION LAYER OF SARNAFIL OR SIKAPLAN BETWEEN THE SUPPORTS AND FIELD MEMBRANE MAY BE WELDED OR UNWELDED AS DESIRED
- 4) SIKA IS NOT RESPONSIBLE FOR LIGHTNING DAMAGE.
- 5) SEALANT IS A MAINTENANCE ITEM AND IS NOT COVERED UNDER THE SARNAFIL WARRANTY.

BUILDING TRUST
800-933-7452



DETAIL NAME:

LIGHTNING ROD

SCALE: N.T.S.

DATE: 6/22

DETAIL NO.: CAN 7-8